

# SAFETY ALERT

Date Circulated: 5-29-25

## Material Alert Bulletin – Honeywell 1-1/4" Fittings

**Company Wide** – It has been brought to our attention that Honeywell (Elster American Meter) Permaserts may have been supplied with undersized O-rings which may result in a leak.

### Actions Required:

1. **Stop Use Immediately** - All employees must discontinue the use of targeted fittings.
2. **Survey Existing Inventory** - Survey existing inventory and pull/quarantine all targeted fittings with a manufacture date between 2/05/2025 and 4/22/2025.  
**\*\*\*Place quarantined fittings in a secure location.\*\*\***
3. **Inspecting Targeted Fittings** - Be aware to inspect all such fittings on new/replaced services or pipeline installations. Fail and do not place into service any targeted fittings.
4. **Inspect and Report** - Inspect and report to your manager all targeted fitting found leaking while in service. Replace such fitting. Tag and retain the leaking fitting (including date of repair and location) and secure with other quarantined fittings.

Please see below for a list of all effected fittings.

MRC PART #	MRC PART DESCRIPTION
C0125132	CAP PLA STAB 1-1/4" CTS .121W
C0125132	CAP PLA STAB 1-1/4" CTS .121W
42029137	COUPLING RED PLA 1-1/4" CTS .121W PE3408 X 1-1/4" IPS SDR10 PE2406, STAB
42029138	COUPLING RED PLA 1-1/4" CTS .121W X 1" CTS .090/.099 OR .102 WALL SIZES, STAB
C0239795	COUPLING RED PLA 2" SDR11 X 1-1/4" CTS .121W STAB
C0646724	RISER ANODELESS 1-1/4" IPS x 1-1/4" CTS .121W PE3408, TRANSITION ELL RISER w/ STAB
C0701099	STOP CURB PLA 1-1/4" CTS .121W 1/4 TURN STAB
C0745922	TEE SERVICE HV PLA EF 2" X 1-1/4" CTS .121W 100PSIG STAB
C0745927	TEE SERVICE HV PLA EF 3" X 1-1/4" CTS .121W 100PSIG STAB
C0745932	TEE SERVICE HV PLA EF 4" X 1-1/4" CTS .121W 100PSIG STAB
C0745937	TEE SERVICE HV PLA EF 6" X 1-1/4" CTS .121W 100PSIG STAB
C0745942	TEE SERVICE HV PLA EF 8" X 1-1/4" CTS .121W 100PSIG STAB